



ALLEGHENY STRUCTURAL COMPONENTS, INC.
3778 Oneida Valley Road
Emlenton, Pennsylvania 16373
Phone: (724) 867-1100
<http://www.alleghenystructural.com>

ADDITIONAL COMPANY:

- **BARRETTE STRUCTURAL, INC.**
555 Rang St-Malo
Trois-Rivieres, Quebec G8V 0A8
Canada
Phone: (800) 263-7265
<http://www.openjoisttriforce.com>

Open Joist 2000® and Open Joist TRIFORCE® Wood Trusses

CSI Section:

06 17 53 Shop-Fabricated Wood Trusses

1.0 RECOGNITION

The Open Joist 2000® and Open Joist TRIFORCE® wood trusses recognized in this report, have been evaluated for equivalent fire-resistant construction to dimension lumber of 2-inch by 10-inch nominal dimension in accordance with Exception 4 of Section R302.13 of the 2018 and 2015 International Residential Code (Section R501.3 of the 2012 International Residential Code) in compliance with the following code editions:

- 2018, 2015 and 2012 International Residential Code® (IRC)

2.0 LIMITATIONS

Use of the wood trusses recognized in this report is subject to the following limitations:

- 2.1** The Open Joist 2000® and Open Joist TRIFORCE® wood trusses have only been evaluated for the fire-resistance requirements noted in Section 1.0. All other requirements shall be evaluated by an approved evaluation service and subject to approval of the code official.
- 2.2.** Selection of the floor trusses for structural loading and its supporting structure shall be designed by an approved structural design professional.
- 2.3** The trusses shall be properly braced in accordance with the installation instructions and the IRC.
- 2.4** Open Joist 2000® and Open Joist TRIFORCE® wood trusses are produced in Emlenton, Pennsylvania and Trois-Rivieres, Quebec, Canada under a quality control program with inspections under the supervision of IAPMO UES.

3.0 PRODUCT USE

3.1 Design: Open Joist 2000® and Open Joist TRIFORCE® wood trusses shall be designed in accordance with manufacturers' design information, ANSI/AWC National Specification for Wood Construction (NDS), and evaluation reports by an approved and accredited certification agency.

3.1.1 Fire-Resistance Construction: A minimum 9³/₈-inch (238 mm) deep truss at a maximum spacing of 24 inches shall (610 mm) be required to offer equivalent fire performance to 2-inch by 10-inch nominal dimension solid sawn lumber and are recognized for installation without the prescribed minimum ½-inch-thick (12.7 mm) gypsum wallboard or 5/₈-inch (15.9 mm) thick wood structural panel membrane in accordance with Exception 4 to the 2018 and 2015 IRC Section R302.13 or Section R501.3 for the 2012 IRC when installed as described in this report.

3.2 Installation: Installation of the Open Joist 2000® and Open Joist TRIFORCE® shall be in accordance with manufacturer's installation guide, this evaluation report and the applicable provisions of the IRC. The joists are imprinted with the words top and bottom on their respective flanges to assure installation is as designed. Where there is a conflict between these documents, the most restrictive provisions shall govern. The manufacturers installation instructions and this report shall be available at the jobsite during construction for use by installers and for quality assurance.

4.0 PRODUCT DESCRIPTION

4.1 General: Open Joist 2000® and Open Joist TRIFORCE® wood trusses are prefabricated open web floor joists constructed of solid-sawn wood. Web members are connected to flanges by adhesively bonded finger joints.

4.1.1 Flanges: The top and bottom flanges are constructed of solid-sawn or finger-jointed Spruce-Pine-Fir (SPF) lumber with a minimum 2-inch by 3-inch nominal dimension.

4.1.2 Web Members: The vertical and diagonal web members are constructed of minimum nominal 2-inch by 2-inch SPF lumber.


An extension is provided on one or both ends of the trusses that may be cut, according to manufacturer's installation instructions, to adjust the length of the joist. The TRIFORCE® truss uses a ¾-inch (15.9 mm) thick wood structural panel or ½-inch (12.7 mm) thick gypsum board attached to each side of a ¾-inch (9.5 mm) thick wood structural panel for the extension and the Open Joist 2000® truss uses a 2-inch by 8-inch solid-sawn lumber web for the extension.



4.1.3 Adhesive: The adhesive used for manufacturing the trusses complies with ASTM D2559 and qualifies under the heat durability performance requirements of ASTM D7247.

5.0 IDENTIFICATION

The bottom flange of the product is imprinted with the manufacturer’s name, manufacturer’s phone number, product name, approved inspection agency, the UES Mark of conformity and evaluation report number (ER-480). Either UES Mark of Conformity may be used as shown below:



6.0 SUBSTANTIATING DATA

- 6.1 Report of Fire-resistance tests in accordance with ASTM E119 from a laboratory in compliance with ISO/IEC 17025.
- 6.2 Technical Assessment of Fire Performance.
- 6.3 Engineering analysis.
- 6.4 Manufacturer’s quality documentation, descriptive literature and installation instructions.

7.0 STATEMENT OF RECOGNITION

This evaluation report describes the results of research carried out by IAPMO Uniform Evaluation Service on Open Joist 2000® and Open Joist TRIFORCE® wood trusses to assess their conformance to the codes shown in Section 1.0 of this report and documents the product’s certification. Open Joist 2000® and Open Joist TRIFORCE® wood trusses are manufactured at locations noted in Section 2.4 of this report under a quality control program with periodic inspections under the supervision of IAPMO UES.

Brian Gerber, P.E., S.E.
Vice President, Technical Operations
Uniform Evaluation Service

Richard Beck, PE, CBO, MCP
Vice President, Uniform Evaluation Service

GP Russ Chaney
CEO, The IAPMO Group

For additional information about this evaluation report please visit www.uniform-es.org or email us at info@uniform-es.org